

DATE FILED: April 18, 2022 5:39 PM
FILING ID: 37078B278BA8D
CASE NUMBER: 2021CV32787

Exhibit N

March 11, 2022

Mr. Doug Dean
Director
Public Utilities Commission
1560 Broadway, Suite 250
Denver, CO 80202

Re: Supplemental Report, January 28, 2022 Incident
Proceeding No. 22I-0086E

Director Dean:

On February 28, 2022, Public Service Company of Colorado (“Public Service” or the “Company”) submitted a report consistent with Rule 3204 regarding a two-part event that impacted its Comanche Generating Station Unit 3 on January 28, 2022.

As explained in that report, discovery work and damage assessment was expected to be complete by March 5, 2022 by Mechanical Dynamics & Analysis (MD&A). Public Service committed to supplementing the report as soon as practical after the assessments identified in the schedule were completed. As a result, Public Service submits this supplemental report.

In conducting the full inspection, MD&A concluded that the stator was undamaged but certain components of the rotating assembly, including the unit’s retaining rings, were affected metallurgically due to significant electrification and need to be repaired. With the exception of the retaining rings, we expect those repairs to be completed by late April. The Company has put in a considerable amount of effort into the sourcing of the retaining rings and is still diligently working to identify a delivery date for this critical component. Due to this uncertainty, the Company does not yet have an expected date as to when Comanche 3 will be returned to service.

Public Service still expects this to be an insurable event. We will continue to supplement this report as new information is known.

Due to the Amended Public Health Order 20-24 Implementing Stay at Home Requirements dated March 25, 2020, Ordering Coloradans to Stay at Home Due to the Presence of COVID-19 in the State, this submission will only be submitted via email. Public Service requests an exemption from the requirement to submit hard copies of this Rule 3204 Incident Report for Commission circulation.

Sincerely,

/s/ Brooke A. Trammell

Brooke A. Trammell
Regional Vice President, Rates and Regulatory Affairs